

FES200MK

Mechanical Plumbed-in Fire Extinguisher System Installation Instructions

This is an FX G-TEC +ADS homologated gas extinguisher system. To maintain optimum performance all fire extinguisher systems should be serviced annually.

IMPORTANT Please read the following before commencing any installation.

1. Do not connect pull cables to the extinguisher until you have completed the entire installation.
2. Check cables for free movement before final connections are made.

Kit Contents:


- 1 FX G-TEC +ADS 2kg pressurised cylinder
- 4 FX Gas nozzles
- 1 Mounting bracket with stainless steel strap
- 1 6mm decabon 3 mtrs
- 1 8mm decabon 2 mtrs
- 1 8 to 8mm Y connector
- 2 8 to 6mm Y connectors
- 8 Tube clips
- 1 FEV 'E' label
- 1 Pull Cable – 12'
- 1 Pull Cable - 6'
- 2 Cable Nipples

INSTALLATION INSTRUCTIONS

1. **BOLT** the cylinder mounting bracket to the vehicle structure **SECURELY**.
2. Mount the pull cables to enable operation **in accordance with current regulations**. One inside the vehicle within easy reach of the driver (and co-driver where applicable) and one on an outside adjacent to the electrical cut out switch. Apply the E Decal label adjacent to the external pull handle.
3. **PLUMBING** - **IMPORTANT** The decabon tube push fits into various fittings, ensure that all push ins are secure. NOTE that the supply from the fire extinguisher should **ENTER** through the **CENTRE** branch of the Y connector (8mm to 8mm) and **EXIT** through the two outlets into the two (8mm to 6mm) Y connectors which then **SUPPLY** the two nozzles in the engine bay and the two nozzles in the cockpit area. *The nozzles are supplied with the rear red release collets not fitted so that the nozzles can be mounted and the retaining nuts screwed on. The collets can then be fitted to each nozzle.* Nozzles should be positioned to enable the spray cone to cover areas at most risk, for example the engine fuel system and turbo. If in doubt ask your local MSA scrutineer to advise.

PLUMBING SCHEMATIC :

MAKE SURE CONNECTIONS ARE SECURELY PUSHED IN.



THIS IS A SAFETY ITEM! CHECK YOUR INSTALLATION CAREFULLY! IF IN DOUBT ASK!

Please Note: FEV FX G-TEC systems are rated for a temperature operation range of -10 to +60 degrees C in accordance with FIA regulations. Users should ensure that where exceeded temperatures are anticipated adequate provision is made to locate the system away from high temperature sources and if necessary fit reflective insulation around the cylinder.

BEFORE EVERY EVENT CHECK SYSTEM CONTENTS, NOZZLES ARE CLEAN AND ALL CONNECTIONS ARE SECURE